



Arkansas Department of Health

STATEMENT OF ACA FINDINGS AND PLAN OF CORRECTION

NAME OF FACILITY Mansfield Juvenile Treatment Center – Girls		STREET ADDRESS, CITY, STATE, ZIP CODE Post Office Box 416 Mansfield, AR 72944			DATE SURVEY COMPLETED 3/29/2011	
CITED STANDARD	SUMMARY STATEMENT OF FINDINGS	CITED STANDARD	FACILITY'S PLAN OF CORRECTION	Date of Completion	CITED STANDARD	RESULT OF FOLLOW-UP
Arkansas State Plumbing Codes 1002.4 Trap Seals Each fixture trap shall have a liquid seal of not less than 2 inches and not more than 4 inches, or deeper for special designs relating to accessible fixtures. Where a trap seal is subject to loss by evaporation, a trap seal primer valve shall be	Arkansas State Plumbing Code 1002.4 Based on the State Plumbing inspection completed on 3/29/2011, the facility shall properly maintain all floor drains.		1002.4: The existing construction that has housed the facility since 1994 was constructed in the 1960's. New construction is slated to be completed in July and all residents will be relocated to those buildings. Shift supervisors and other designees periodically pour water or cooking oil down the drains of showers that are not currently in use to avoid sewer gas issues. This has taken place as needed for many years.	3/29/11		This deficiency was cleared during the follow-up survey of 5/24/11.



Arkansas Department of Health

STATEMENT OF ACA FINDINGS AND PLAN OF CORRECTION

installed.						
<p>Environmental Health Services</p> <p>Rules and Regulations Pertaining to General Sanitation</p> <p>Section VIII. (C) Each lavatory must be provided with an adequate supply of hand cleaning soap or detergent and an adequate supply of single-use sanitary towels or an approved hand drying device.</p>	<p>Environmental Health Services Section VIII C.</p> <p>Based on the 3/29/2011, 11:20 AM – 11:30 AM tour observations of the girls’ bathrooms there were no hand drying towels available or an approved hand drying device.</p>		<p>Sec. VIII C: All restrooms are to be cleaned and stocked twice daily by clients on first and second shift. These chores are assigned to clients as part of their daily dorm “details.” A supervisor meeting was held on 3/29 to reinforce that Team Assistants are to inspect all details upon completion and the Shift Supervisor will complete a thorough inspection to ensure that the details are completed in a satisfactory manner</p>			<p>This deficiency was cleared during a follow-up survey done on 5/24/11.</p>